

# **Model RP40**

# REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTER

Job Name:	Contractor:
Job Location:	P.O. Number:
Engineer:	Representative:
Tag:	Wholesale Distributor:

#### **SPECIFICATIONS**

The 2 ½" - 10" Reduced Pressure Principle Backflow Preventer shall be an Apollo® Model RP40. The assembly shall be manufactured in America. The epoxy-coated ductile iron body shall be configured with individuallyaccessible top-mounted check valves. The relief valve portion shall be positioned at the bottom of the assembly with a separate center-accessed cover. The replaceable seat rings shall be bronze threaded-in type and the reversible seat discs shall be silicone rubber. The Apollo® domestic ball valve test cocks shall have stainless steel handles. The assembly shall prevent contamination of the potable water supply due to back-siphonage or backpressure from substances that are health or nonhealth hazards. The pressure drop across the assembly shall be documented by USC's FCCC&HR approval curves.

#### **FEATURES**

- Replaceable seat rings
- · Reversible seat discs
- Individual access to check valves
- Designed for easy maintenance
- · Corrosion resistant epoxy-coated ductile iron body
- MADE IN THE USA

### **MATERIAL SPECIFICATIONS**

Part Name	Material		
Body	Epoxy-coated (FDA)		
_	Ductile Iron		
Relief Valve Body	Bronze		
Covers	Epoxy-coated (FDA)		
	Ductile Iron		
Check Valve Seats	Bronze		
Springs	Stainless Steel		
Seat Discs	EPDM & Silicone		
Fasteners	Stainless Steel		

# PERFORMANCE RATING

Maximum Working Pressure 175 psi Hydrostatic Test Pressure 350 psi Temperature Range 33 °F – 140 °F

#### **APPROVALS**


ASSE<sup>®</sup> 1013, CSA<sup>®</sup> B64.4, IAPMO listed, USC's FCCC&HR, AWWA C-511, UL\*, and FM\*.

\*UL and FM installations must include indicating-type shutoff valves.





# ORDERING INFORMATION



# Y-STRAINER

- □ **0** None (Standard)
- ☐ 1 With Y-Strainer (Flanged, shipped loose)

### SIZE

# **SHUT-OFF VALVES (Inlet x Outlet)**

- □ 1 Less Shut-off Valves (flanged-end body)
- □ 2 NRS Flanged x NRS Flanged
- ☐ 3 OS&Y Flanged x OS&Y Flanged
- ☐ 5 Epoxy-coated Flanged Ball Valves
- ☐ 6 OS&Y Flg x Post Indicator Flg\*\*
- **☐ 7** OS&Y Flg x OS&Y Grv
- □ 8 OS&Y Grv x OS&Y Grv
- □ 10 OS&Y Flg x Post Indicator Grv\*\*

<sup>\*\*</sup>Post Indicator option not available in 2 1/2" size

# **Model RP40**


# REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTER


# **DIMENSIONS (in.) - WEIGHTS (lbs.)**

Size	2 1/2"	3"	4"	6"	8"	10"
A*	37 5/16	38 5/16	46 3/4	63 3/8	75 3/8	88 3/8
B*	22 1/16	22 1/16	28 1/2	42 1/8	52 1/8	62 1/8
(flanged-end body)	22 1/10	22 1/10	20 1/2	72 1/0	JZ 1/0	02 1/0
C*	47 15/16	49 15/16	61 3/4	81 7/8	96 7/8	114 5/8
D (NRS)	20 7/8	21 7/8	25 3/16	30 1/2	38 1/2	44
D(OS&Y Open)	25 7/8	28 3/8	33 3/16	41 5/8	53 3/4	63 1/4
E (NRS)	11 3/8	12 3/8	14 3/4	19	22 1/2	26 1/2
E (OS&Y Open)	16 3/8	18 7/8	22 3/4	30 1/8	37 3/4	45 3/4
F	9 5/8	10 3/8	11 7/8	14 5/8	16 3/4	19 1/4
G	7	7 1/2	9	11	13 1/2	16
Test Cocks (NPT)	1/2	1/2	1/2	3/4	3/4	3/4
Net Wt.	120	120 122	196	430	715	1443
(Less Valves)		122				
Net Wt. (w/ OS&Y	229	229 259	402	754	1210	2286
shut-off valves)				, 54		

# **FLOW CURVES**

(•) Rated flow as determined by USC's FCCC&HR and ASSE design performance standards.





Conbraco Industries, Inc. 701 Matthews Mint Hill Rd. Matthews NC 28105 USA; www.apollovalves.com; 704-841-6000

<sup>\*</sup> Nominal dimensions are shown. Allowances must be made for manufacturers' tolerances.